









FLOOR PLAN 1:100





-  SD Smoke detector with sounder
-  HD Heat detector with sounder
-  E Emergency light with 2 hour battery back up
-  EE External Emergency light with 2 hour battery back up
-  exit Emergency exit light with 2 hour battery back up
-  CPA Manual FA Call point
-  FAP Fire alarm panel

Fire Warning System to comply with British Standard 5839: Part 1 : 2019

Every part of an escape route to have artificial lighting supplied by a protected circuit that provides a level of illumination not less than that recommended in BS 5266 Part 1 2005 (Maintained -2 hour duration) and BS EN 1838: 1999 (OR BS 5266-7: 1999) Firefighting Equipment to comply with British Standard EN3, British Standard 7863 : 1996, British Standard 5306-8:200

Signs and Notices to comply with the Health and Safety (Safety Signs and Signals) Regulations 1996 and/or British Standard 5499: Part 1 : 1990.

-  Extent of property
-  Extent of Customer Area
-  Area used to display alcohol (total frontage approx. 18.5m²)



LOCATION PLAN 1:2500

Note: Drawing prepared for application for Licensing Board only.

Client
MULL HOTELS LTD.

Project
**PORT NAN GAEL SHOP,
PENNYGHAEL,
ISLE OF MULL,
PA70 6HB**

Drawing
FLOOR PLAN

LICENSING DRAWING

Drawn by CMD Date: MAY 2024
Drawing Scale: A2 @ 1:100
CAD Filename:

Beaton + McMurphy
architects

tigh na glaic, taynuilt, argyll. pa35 1jw
tel - 01866 892350 fax - 01866 892320 e-mail mail@bmarchitects.co.uk web www.bmarchitects.co.uk

Drawing No. **2414** | Revision **LD 01** | **A**